

Waltham Farmers' Market

P.O. Box 541161, Waltham MA 02454

Market Manager: Leo Keightley • (781) 899-0324 • manager@walthamfarmersmarket.org

Rules for ELECTRIC POWER at the 2017 Waltham Farmers' Market

General

A limited number of circuits and service locations are available.

To obtain electric power the following **Hookup Requirements** must be met.

Hookup Requirements (Approval)

- **Approval by Market Manager** (contact manager@walthamfarmersmarket.org to request approval)
- **Maximum power** use is established during approval process (circuits are shared). Know your power requirements. The Manager may be able to help determine your requirements if you aren't sure.
- **Approved extension cord** must be supplied by the vendor (see **Extension Cord Requirements**). The extension cord length and wire gauge must be approved by the Market Manager.

Extension Cord Requirements

- **Outdoor rating:** (this is specified on the cord packaging)
- **Wire Gauge:** 16, 14, or 12 gauge as approved by Market Manager
- **Straight-in plug:** (not angled .. angled plugs block adjacent outlet)
- **Length:** Sufficient to run from assigned outlet to 3 feet inside vendor canopy. all connections to vendor equipment are made inside vendor canopy.

